

**RAJASTHAN FIRE & EMERGENCY SERVICE, BEHROR**

Ref. No.:

Date: 04-03-2020

**NO OBJECTION CERTIFICATE**

Certified that I have inspected the site of RAJASTHAN PUBLIC  
SCHOOL, NARNAUL-BEHROR ROAD, JAKHARANA

District- Alwar (Raj.) at Behror on dated 02-03-2020

The principal has already installed Eight ABC (Stored Pressure) fire extinguishers 5kg capacity each ISI Mark and Two Water Co<sub>2</sub> type fire extinguishers 9 liter Capacity each ISI Mark & Eight Fire Buckets found good conditions for safety from fire point of view.

The above certificate is issued after inspection and tested by the undersigned and valid for One Year From 04-03-20 to

03-03-2021.



अग्निशमन अधिकारी

नगर परिषद, अलावर (राज0)